

WEST BENGAL MEDICAL SERVICES CORPORATION LTD

(Wholly Owned by the Government of West Bengal)

CIN: U85110WB2008SGC126373

Regd. Off. : Swasthya Sathi, GN-29, Sector-V, Salt Lake, Kolkata-700091

Telephone: (033) 40340300 | Fax: (033) 40340400

E-mail: info@wbmsc.gov.in | Website: www.wbmsc.gov.in

Memo No.: WBMSC/AAES- 678/1110

Date: 31/03/2017

ORDER

Administrative Approval & Expenditure Sanction is hereby accorded for 'Electrical work for emergent replacement of 12 Volts 42Ah SMF Battery for 2 Nos 20 KVA UPS at SNCU of Diamond Harbour District Hospital, South 24 Parganas' at an estimated cost of Rs. 3,04,248.00 (Rupees Three Lakh Four Thousand Two Hundred Forty Eight) only as per approved vide AAFS no. 147-MS/HF/P/MS/7H-19/2017 Dated 28.03.2017 out of the 13th Finance Commission for Strengthening of public Health infrastructure approved in Incentive Grants list as appeared in No. 29 for reduction in Infant Mortality Rate to State Government . The details are as follows:

Sl. No.	Particulars	Amount (Rs.)
1	Electrical work of emergency replacement of 12 Volts 42Ah SMF Battery for 2 Nos 20 KVA UPS at SNCU of Diamond Harbour District Hospital, Diamond Harbour Health District	2,96,827.00
2	Contingency @ 2.5%	7,421.00
Total:		3,04,248.00

The work will be executed by the Executive Engineer, South 24 Parganas Electrical Division, PWD & Ex-officio Executive Engineer, West Bengal Medical Services Corporation Limited., as per norms stated in the order of the Health & Family Welfare Dept., M.S. Branch, vide no. HF/O/MS/384/W-39-12 dt. 01.06.2012 read with Notification No. 86-W(C)-1M-106/11 dt. 06.02.2012 and Memorandum no 37-W(C)-1M-106/11 dated 17.01.2012 of Public Works Department, Government of West Bengal.


Managing Director

Memo No: WBMSC/AAES- 678/1110/1(10)

Date: 31.03.2017

Copy forwarded for information and necessary action to:

1. Joint Secretary, MS Branch, Health & Family Welfare Department.
2. Programme officer, NHM & Deputy Secretary , Health & Family Welfare Department
3. CMOH, Diamond Harbour Health District
4. Superintendent, Diamond Harbour District Hospital
5. Superintending Engineer, Southern Electrical Circle, PWD & Ex-Officio Superintending Engineer, West Bengal Medical Services Corporation Limited.
6. Manager (Accounts), West Bengal Medical Services Corporation Limited
7. Executive Engineer, South 24 Parganas Electrical Division, PWD & Ex-officio Executive Engineer, West Bengal Medical Services Corporation Limited.
8. Consultant Project Engineer (Civil), West Bengal Medical Services Corporation Limited
9. Consultant Electrical Engineer , West Bengal Medical Services Corporation Limited
10. Office Copy


Managing Director

AGM
29/3

U.O.
29/03/17

OPB (U) / CEF / M (MCS)

28.03.17

GOVERNMENT OF WEST BENGAL
DEPARTMENT OF HEALTH & FAMILY WELFARE
M.S. BRANCH
SWASTHYA BHAVAN, GN- 29, SECTOR- V
SALT LAKE CITY, KOLKATA- 700 091

No. 147-MS/HF/P/MS/7H-19/2017

Dated: 28.03.2017

From: Joint Secretary.
to the Government of West Bengal.

To: Managing Director, WBMSCL
Swasthya Bhawan Complex
GN-29, Sector -V, Salt Lake, Kolkata-700091.

926
29/03/2017

29/03/17

ORDER

1. The undersigned is directed by the order of the Governor to say that the Governor has been pleased to accord Administrative Approval & Financial Sanction in respect of a total amount of Rs. 3,08,700/- (Rupees Three Lakh Eight Thousand Seven Hundred) for emergent replacement of 12 volts 42 Ah SMF Battery for 2 Nos. 20 KVA UPS at SNCU at Diamond Harbour District Hospital.
2. The work will be executed through West Bengal Medical Service Corporation Ltd(WBMSCL).
3. Expenditure in connection with the construction of SNCU would be met out of the 13th Finance Commission for Strengthening of public Health infrastructure approved in Incentive Grants list as appeared in No.29 for reduction in Infant Mortality Rate to State Government(s), credited to the Deposit Fund Account of the West Bengal Medical Services Corporation Ltd. from time to time.
4. Order issues with concurrence of Financial Advisor of the Health & Family Welfare Department in terms of his U.O.No. 2392 dt. 25.03.2017
5. All concerned are being suitably informed.

Selal
28.03.17.

Joint Secretary
to the Government of West Bengal.

No. 147-MS/1(10)/HF/P/MS/7H-19/2017

Dated: 28.03.2017

Copy forwarded for information & necessary action to:-

1. DHS & EX-Officio Secretary, H& FW Department.
2. Project Officer & Ex-Officio Deputy Secretary, NHM.
3. The Joint Director ,(P&D).
4. The General Manager, W.B.M.S.C.L .The original two estimates for Rs. 3,08,700/- is enclosed for necessary action.
5. Financial Advisor, Health & Family Welfare Dept.

6. Executive Engineer, P.W.D., Diamond Harbour Electrical Sub- Division.
7. CMOH, Diamond Harbour Health District, Diamond Harbour ,South 24 parganas, Pin-743 331.
8. IT Cell for website posting.
9. Office Copy
10. Guard File.

Selvi

28.03.17

Joint Secretary.

to the Government of West Bengal.

ESTIMATE

Name of Work : Emergent Replacement of 12Volts 42Ah SMF Battery for 2 Nos. 20 KVA UPS at S.N.C.U. of Diamond Harbour District Hospital, South 24 Parganas.

Report : This estimate has been framed to meet the probable cost of expenditure for replacement of old & exhausted sealed type maintenance free battery of 12V 42Ah capacity for 2 Nos. 20 KVA U.P.S. of SNCU, Diamond Harbour District Hospital. After inspection it is noticed that gradually existing batteries of 2 Nos. UPS are becoming in deform shape due to long use since March'2014. During the load shedding uninterrupted power supply to different emergency power plugs for sick new born babies from these 2 Nos U.P.S. before coming the DG power, For smooth run of these 2 Nos. UPS, 64 Nos. batteries(32 Nos batteries for each UPS) should be replaced by new batteries for which the cost has been included in this estimate & put up for necessary administrative approval & allotment of fund from the appropriate authority and allotment of fund for early execution of the work.

Sl. No.	Description of the work	Qty	Rate	Unit	Amount
1	Replacement of defective & exhausted Sealed Maintenance Battery (S.M.F) by Supply & delivery of new 12Volt/42Ah SMF Batteries for 2 Nos. of 20 KVA UPS. (Make: Exide. Cat No. -EP42-12). <i>64 Nos. 42Ah</i>	64 Nos.	4640.00	Ea	296960.00
					Rs. 296960.00
					Add. LWC @ 1% Rs. 2969.60
					Total Rs. 299929.60
					Say Rs. 299930.00

less Cost unexhausted Batteries

Rupees Two Lac Ninety Nine Thousand Nine Hundred Thirty only

30/11/16
Assistant Engineer, PWD
Diamond Harbour Electrical Sub- Division

Adding LWC @ 1% Rs. 2969.60
Adding Administrative @ 1% of WBSCL @ 1% Rs. 2969.60

25/11/17
Superintendent
Diamond Harbour District Hospital
Diamond Harbour Health District
Diamond Harbour, South 24 Parganas

25/11/17
Chief Medical Officer of Health
Diamond Harbour Health District
South 24 Parganas

Checked.

24/11/17
Consultant Eng. (Elect.)
West Bengal Medical Services Corporation Ltd