

WEST BENGAL MEDICAL SERVICES CORPORATION LIMITED

(Wholly Owned by the Government of West Bengal)

Registered Office: Swasthya Sathi, GN-29, Sector-V, Salt Lake, Kolkata- 700091

Phone: 033-4034-0300 ♦ Email: info@wbmsc.gov.in ♦ website: www.wbmsc.gov.in

I.T.B No: WBMSC/NIT- 234/2018

Date: 28/11/2018

NOTICE INVITING TENDER PACKAGE-C

Sealed TENDER is invited from the Bonafide, Resourceful, Reliable and Experienced Electrical agency of PWD, I&W Dept. WBSEDCL, Railway and other Govt. Dept./Under Taking for the work of "Filtration of Transformer Oil along with BDV & Acidity Test with supply and replacements of Transformer Oil & Silica Gel for breather" at Srirampore, Arambagh, M.R.Bangur, Asansole, Kalna, Bongaon & Basirhat Super Speciality Hospital.

Brief description of work	Last date and time of TENDER submission	Date & Time of Opening Of TENDER
"Filtration of Transformer Oil along with BDV & Acidity Test with supply and replacements of Transformer Oil & Silica Gel for breather" at Srirampore, Arambagh, M.R.Bangur, Asansole, Kalna, Bongaon & Basirhat Super Speciality Hospital.	04/12/2018; 2.00 pm	04/12/2018; 3.00 pm
BID Opening Venue	West Bengal Medical Services Corporation Ltd, Swasthya Sathi Building, GN -29 , Sector – V, Salt Lake, Kolkata – 700091.	

Prospective bidders are requested to submit the TENDER in a sealed cover addressed to the Managing Director, West Bengal Medical Services Corporation Ltd, Swasthya Sathi Building, GN - 29 , Sector – V, Salt Lake, Kolkata – 700091 within the stipulated date & time.

Scope of work:

1	"Filtration of Transformer Oil along with BDV & Acidity Test with supply and replacements of Transformer Oil & Silica Gel for breather" at Jhargram, Ghatal, Gopiballavpur, Bishnupur, Raghunathpur, Pashkura & Egra Super Speciality Hospital.	
2	Time allowed for completion of work	40 days from the date of issue of work order.
3	Eligibility of Participating vendor: Bonafide, reliable and resourceful vendors having credentials of same nature of work would only be accepted.	
4	Validity of TENDER	365 days from the date of submission of TENDER.WBMSCCL can issue the work order for the following sites phase wise during this period.

5	Delivery of Materials	All materials/machines related with the will have to be supplied at site by the vendor at his own risk and cost including cost of transportation, labour charges and all other taxes and duties etc. Authorized Representative of WBMSCL at site will monitoring & certify the whole Materials.
---	-----------------------	---

BOQ & TECHNICAL SPECIFICATIONS

All parameters mentioned in the BOQ are Essential. Bidder has to comply with all Essential parameters.

Bill of Quantity

Sl No	Description of Transformer	Location of Transformer	Job Description	Qty.	Unit
1	One no. 11/.415 KV, 1000 KVA, ONAN DYN11, Oil filled distribution. Transformer, Main oil tank capacity & OLTC tank capacity 1517 Liters + 210 ltrs, (Hence total quantity to be filtered = 1727 +/-10% liters), Make : Voltamp	Srirampore SSH	Transformer oil filtration.	1	Items
			Conduct BDV test of top & bottom sample of transformer oil, before & after filtration and report submission.	1	Items
			Conduct acidity test as per I.E. rule and report submission.	1	Items
			Supply, filtered and top up of Trans oil/power oil make Transformer oil. (Above mentioned transformer oil should be delivered at site in sealed container)	209	Ltrs.
2	One no. 11/.415 KV, 1000 KVA, ONAN DYN11, Oil filled distribution. Transformer, Main oil tank capacity & OLTC tank capacity 1517 Liters + 210 ltrs, (Hence total quantity to be filtered = 1727 +/-10% liters), Make : Voltamp	Arambagh SSH	Transformer oil filtration.	1	Items
			Conduct BDV test of top & bottom sample of transformer oil, before & after filtration and report submission.	1	Items
			Conduct acidity test as per I.E. rule and report submission.	1	Items
			Supply, filtered and top up of Trans oil/power oil make Transformer oil. (Above mentioned transformer oil should be delivered at site in sealed container)	209	Ltrs.
3	One no. 11/.415 KV, 800 KVA, ONAN DYN11, Oil filled distribution. Transformer, Main oil tank capacity 650 liters +/- 10% Make :	M.R.Bangur SSH	Transformer oil filtration.	2	Item
			Conduct BDV test of top & bottom sample of transformer oil, before & after filtration and report submission.	2	Item
			Conduct acidity test as per I.E. rule and report submission.	2	Item