



**WEST BENGAL MEDICAL SERVICES CORPORATION LTD.**  
(Wholly owned by the Government of West Bengal)  
Swasthya Sathi, GN-29, Sector-V, Salt Lake, Kolkata-700 091.

**CORRIGENDUM - II**

**TO**

***BIDDING DOCUMENTS***

**FOR**

***Design, Supply, Installation, Commissioning, Operation & Maintenance of Medical Gas Pipeline System  
(MGPS) in 7 District & Sub-Divisional Hospitals of West Bengal***

**Bid Reference No.: WBMSCL/NIT- 47/2017**

**Dated - 09. 08.2017**

**2<sup>nd</sup> Call of Bid Reference No.: WBMSCL/NIT-60/2016**

**Dated - 05.10.2016**

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision	Changed Clause / Provision				
1	2	Contents		<i>Sl.</i>	<i>Documents</i>	<i>Page Nos.</i>	<i>Sl.</i>	<i>Documents</i>	<i>Page Nos.</i>
				1	Section – I : Notice Inviting e-Tender (e-NIT)	3 – 10	1	Section – I : Notice Inviting e-Tender (e-NIT)	3 – 9
				2	Section – II : Instructions to Bidders (ITB)	11 - 40	2	Section – II : Instructions to Bidders (ITB)	10 – 38
				3	Section – III : Schedule of Requirements (SoR)	41 – 75	3	Section – III : Schedule of Requirements (SoR)	39 – 75
				4	Section – IV : Bidding Forms (BDF)	76 – 113	4	Section – IV : Bidding Forms (BDF)	76 – 109
				5	Section – V : General Conditions of Contract (GCC)	114 – 138	5	Section – V : General Conditions of Contract (GCC)	110 – 134
				6	Section – VI : Contract Forms (COF)	139 – 144	6	Section – VI : Contract Forms (COF)	135 – 140
				7	Section – VII : Drawings	145	7	Section – VII : Drawings	141 – 160
2	24	Section – II Instructions to Bidders (ITB)	11.3	<p><i>“The Financial Bid is to be provided in the Bill of Quantities (BoQ), which shall be the sum total of the following:</i></p> <p>(a) <i>Contract Price for design, supply of equipment, installation, and commissioning charges from the date of commissioning and handover of MGPS</i></p> <p>(b) <i>Comprehensive operation and maintenance charges for the 1<sup>st</sup> year</i></p> <p>(c) <i>Comprehensive operation and maintenance charges for the 2<sup>nd</sup> year</i></p> <p>(d) <i>Comprehensive operation and maintenance charges for the 3<sup>rd</sup> year</i></p> <p>(e) <i>Comprehensive operation and maintenance</i></p>	<p><i>“The Financial Bid is to be provided in the Bill of Quantities (BOQ), which shall be the sum total of the following:</i></p> <p>(a) <i>Contract Price for design, supply of equipment, installation, and commissioning charges from the date of commissioning and handover of MGPS</i></p> <p>(b) <i>Comprehensive operation and maintenance charges for the 1<sup>st</sup> year</i></p> <p>(c) <i>Comprehensive operation and maintenance charges for the 2<sup>nd</sup> year</i></p> <p>(d) <i>Comprehensive operation and maintenance charges for the 3<sup>rd</sup> year</i></p> <p>(e) <i>Comprehensive operation and maintenance</i></p>				

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision	Changed Clause / Provision
				<p>charges for the 4<sup>th</sup> year</p> <p>(f) Comprehensive operation and maintenance charges for the 5<sup>th</sup> year.</p> <p>The rates quoted by the bidder shall be inclusive of all applicable taxes, rates and levies. In addition, the bidder will be required to submit the Price Schedule in portable document file (PDF) format, the breakup of contract price for design, supply of equipment, installation, commissioning and operation and comprehensive maintenance charges for 1 (one) year from the date of commissioning and handover of MGPS as per Form - 14 of the Bidding Forms.</p> <p>N.B. - (1) The bidder is to quote the rate online in the space marked for quoting rate in the BoQ. Only BoQ rate will be considered for evaluation of Financial Bid.</p> <p>(2) The bidders shall have to quote their rates for each and every category of work for each of the facilities in the Price Schedule, failing which its bid will be summarily rejected.</p> <p>(3) Only downloaded copies of the above documents are to be uploaded, virus scanned and digitally signed by the bidder.</p> <p>(4) The sum of the rates quoted in the Price Schedule shall match with the total price quoted in the BoQ. If there is any discrepancy between the total of the rates quoted in the Price Schedule and the BoQ, the Price Schedule shall prevail over the BoQ."</p>	<p>charges for the 4<sup>th</sup> year</p> <p>(f) Comprehensive operation and maintenance charges for the 5<sup>th</sup> year.</p> <p>The rates quoted by the bidder shall be exclusive of applicable GST. In addition, the bidder will be required to submit the following documents:</p> <p>(i) Price Schedule in portable document file (PDF) format containing the breakup of Contract Price for design, supply of equipment, installation, commissioning and comprehensive operation and maintenance charges for each of the 5 years (excluding GST) as per Form - 14 of the Bidding Forms.</p> <p>(ii) Statement of Breakup of Duties and Taxes in portable document file (PDF) format containing the breakup of Contract Price for design, supply of equipment, installation, commissioning and operation and comprehensive operation and maintenance charges for each of the 5 years including the percentage of GST and the amount of GST payable by the bidder for the works comprising design, supply of equipment, installation, and commissioning charges and comprehensive operation and maintenance charges for 1 (one) year from the date of commissioning and handover of MGPS as per Form - 15 of the Bidding Forms.</p> <p>N.B. - (1) The bidder is to quote the rate online in the space marked for quoting rate in the BOQ. Only BOQ</p>

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision	Changed Clause / Provision
					<p>rate and not the GST amount will be considered for evaluation of Financial Bid.</p> <p>(2) The bidders shall have to quote their rates for each and every category of Works for each of the facilities in the Price Schedule, failing which its bid will be summarily rejected.</p> <p>(3) Only downloaded copies of the above documents are to be uploaded, virus scanned and digitally signed by the bidder.</p> <p>(4) The sum of the rates quoted in the Price Schedule shall match with the total price quoted in the BOQ. If there is any discrepancy between the total of the rates quoted in the Price Schedule and the BOQ, the Price Schedule shall prevail over the BOQ."</p>
3	25	Section - II Instructions to Bidders (ITB)	13.2	"The price to be quoted in the Financial Bid, in accordance with the BoQ, shall be the rate (in INR) to be charged by the bidder for all the hospitals, which shall be inclusive of all rates, levies and taxes. Only a fixed rate in INR (up to two decimal places) can be quoted by the bidder."	"The price to be quoted in the Financial Bid, in accordance with the BOQ, shall be the rate (in INR) for the sum total of all the categories of Works to be charged by the bidder for all the 7 hospitals, which shall be exclusive of GST. Only a fixed rate in INR (up to two decimal places) can be quoted by the bidder."
4	85	Section - IV Bidding Forms (BDF)	Form 7(c)	"Apart from the contract price (upon deduction of taxes, as may be applicable) as per the Bidding Documents, nothing extra or additional, on any head or account will be paid by you to me/ us."	"Apart from the contract price (upon deduction of taxes, as may be applicable) as per the Bidding Documents and reimbursement of GST paid at actuals, nothing extra or additional, on any head or account will be paid by you to me/ us."
5	123	Section - V General Conditions of Contract (GCC)	20.2	"GST on all equipment supplied and services rendered will be required to be borne by the Contractor at actuals."	"GST on all equipment supplied and services rendered will be required to be borne by the Contractor at actuals, which shall be reimbursed by the Corporation. Such reimbursement shall be claimed by the Contractor in the pro-rata bills raised on the Corporation in terms of Clause 21 of the GCC."

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision	Changed Clause / Provision
6	126	Section - V General Conditions of Contract (GCC)	22.4(a)	<i>"The Corporation shall recover from the Contractor, liquidated damages on the equipment and services, which the Corporation has failed to deliver within the Delivery Schedule stipulated in the contract."</i>	<i>"The Corporation shall recover from the Contractor, liquidated damages on the equipment and services, which the Contractor has failed to deliver within the Delivery Schedule stipulated in the contract."</i>

Form - 14 in Section - IV of the Bidding Documents (Bidding Forms) is to be replaced with the following Form - 14:

**FORM - 14**

**PRICE SCHEDULE**

(Breakup of cost)

Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
<b>1</b>	<b>OXYGEN SYSTEM</b>		1	2	3	4	5	6	7			
1.1	2 x 8 size manifold complete with middle frame with chain for individual cylinder along with Tail Pipe and Non Return Valve for every cylinder and Isolation Valve, Safety Valve, etc. as required for the complete manifold system	Set	1	1	1	1	1	1	1	7		

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision			
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR	
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)	
1.2	Semi-automatic control panel for Oxygen with automatic changeover facilities from running bank to reserve bank of cylinders and having non-halogenated polymer at the high pressure side of high flow Regulators	Set	1	1	1	1	1	1	1	1	7		
1.3	4 cylinder manifold (Emergency supply) complete with middle frame with chain for individual cylinder along with Non Return Valves and tail pipes for every cylinder and with high flow Regulator having non-halogenated polymer at the higher pressure side. In case of reduction of pressure of the main manifold, there should be automatic changeover from main manifold to emergency manifold with audio-visual alarm	Set	1	1	1	1	1	1	1	1	7		
1.4	Surface/panel/pendant mounted front loading double lock Oxygen outlets with	Nos	102	46	79	66	41	34	82	450			

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
	matching Adapters											
1.5	H.P. tubing having anti static core white color 5mtrs with kit conversion for Oxygen	Set	7	5	7	5	2	5	1	32		
<b>2</b>	<b>NITROUS OXIDE SYSTEM</b>											
2.1	2 x 2 size manifold (Primary & Secondary supply) complete with middle frame with chain for individual cylinder along with Non Return Valves for every cylinder.	Set	1	1	1	1	1	1	1	7		
2.2	Semi-automatic control panel for Nitrous Oxide with automatic changeover facilities from running bank to reserve bank of cylinders	Set	1	1	1	1	1	1	1	7		
2.3	1 cylinder Emergency Nitrous oxide arrangement using a high flow double stage Regulator with gauges	Set	1	1	1	1	1	1	1	7		

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision							Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR	
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferrin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)	
2.4	Surface/panel/pendant mounted front loading double lock Nitrous Oxide outlets with matching Adapters	Nos	7	5	7	5	2	5	1	32			
2.5	H.P. tubing having antistatic core Blue color 5mtrs with Kit conversion for Nitrous Oxide as per ISO Standards	Set	7	5	7	5	2	5	1	32			
<b>3</b>	<b>MEDICAL AIR SYSTEM</b>												
3.1	Compressed Air System Consisting of 2 nos of non-lubricated, Reciprocating, Tank Mounted Air Compressors (Anest Iwata make Model), each of 10 HP Motor with 37 cfm capacity at 8.5Kg/cm2 pressure with Isolation Valve for each compressor Air drier with bypass valve arrangement Duplex Pressure Reducing Unit for Air 4 bar valve arrangement	Set	1	1	1	1	1	1	1	7			



Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
	Flexible High pressure SS Hose for each compressor NRV for each compressor Safety Valve in the Air Receiver Pressure Gauge with Valve Arrangement in the Air Receiver Valve - Upstream of Air Receiver Automatic Drain Arrangement for air receivers Air Compressor By pass line Pressure Gauge with Valve arrangement in Main line Isolation Valve in the main line											
3.2	Supply, Installation, Testing and commissioning of <b>3-stage air filtration system (suitable for 10HP Compressor) as per ISO 8573.1 Class 1-2-1.</b>	Set	1	1	1	1	1	1	1	7		

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferrin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
3.3	Surface/panel/pendant mounted front loading double lock Medical Air-4 bar Outlets with matching Adapters	Set	47	25	37	31	14	17	41	212		
3.4	HP colour coded black Tubing having anti static core as per ISO Standards	Mtr	35	25	35	25	10	25	5	160		
<b>4</b>	<b>VACUUM SYSTEM</b>											
4.1	Vacuum Central System: Supply, Installation, Testing and commissioning of Duplex vacuum pumps should be air cooled type, Reciprocating, 2 nos. of Ingersoll Rand make Model V255 x 5 HP Motor with 1 no. Receiver of 1000 litres capacity NRV for each Vacuum Pump Isolation Valve for each Vacuum Pump (42 mm) Valve - Upstream of Vacuum Receiver	Set	1	1	1	1	1	1	1	7		

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision			
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR	
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)	
	Vacuum Drain valve with flask arrangement Filters for each vacuum pump Silencer for each vacuum pump.												
4.2	Surface/panel/pendant mounted front loading double lock Vacuum Outlets with matching Adapters	Nos	62	34	49	40	29	22	42	278			
4.3	High Pressure color coded yellow Tubing having anti static core as per ISO Standards	Mtr	35	25	35	25	10	25	5	160			
5	<b>ELECTRICAL CONTROL PANEL FOR COMPRESSOR &amp; VACUUM SYSTEM</b>												
5.1	Supply, Installation, Testing and commissioning of Combined Electrical Control Panel for Vacuum System (5HP each) & Compressed Air system (10HP each) with Duplex/Cascading / Sequencing facilities and complete with plant Room wiring .	Set	1	1	1	1	1	1	1	7			

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
6	<b>PIPELINE DISTRIBUTION SYSTEM</b>											
6.1	Supply, Installation, Testing and commissioning of <b>copper piping with Lloyds' Certified Copper Pipes</b> as per BS EN 13348: 2008. Pipe sizes will be as follows:											
6.1.1	12 mm OD x 0.7 mm thick	Mtr	264	120	192	170	111	72	240	1169		
6.1.2	15 mm OD x 0.9 mm thick	Mtr	580	500	590	505	352	231	355	3113		
6.1.3	22 mm OD x 0.9 mm thick	Mtr	633	565	542	370	379	272	352	3113		
6.1.4	28 mm OD x 0.9 mm thick	Mtr	274	225	195	140	126	114	160	1234		
6.1.5	42 mm OD x 1.2 mm thick	Mtr	216	135	95	35	45	45	63	634		
6.1.6	54 mm OD x 1.2 mm thick	Mtr	105	135	95	0	0	0	10	345		
6.2	<b>Isolation Valve (factory-degreased) with brass adapters</b>											
6.2.1	15mm	Set	1	1	1	2	1	3	2	11		
6.2.2	22mm	Set	7	9	6	5	6	7	7	47		

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferrin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
6.2.3	28mm	Set	4	5	5	4	6	4	6	34		
6.2.4	42mm	Set	1	1	1	1	1	1	2	8		
6.2.5	54mm	Set	1	1	1	0	0	0	1	4		
<b>6.3</b>	<b>VALVE BOX with NIST connectors for oxygen with lockable arrangement and breakable glass cover.</b>											
6.3.1	2 valve configuration with size 15 O2, 22 VAC	Nos	1	1	1	0	1	0	0	4		
6.3.2	3 valve configuration with size 15 O2, 15 MA4, 22 VAC	Nos	2	3	2	3	1	1	3	15		
6.3.3	4 valve configuration with size 15 O2, 15 N2O, 15 MA4, 22 VAC	Nos	5	5	4	4	2	3	1	24		
<b>6.4</b>	<b>ALARM SYSTEM : Providing and fixing digital alarm system for Medical gas system complete consisting of pressure sensors, panel and the control cabling, all wiring shall be within 1mm sq multi core data cable, PVC pipe</b>											

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
	for data cable. Panel shall be self contained low voltage (less than 24 V)											
6.4.1	2 service alarm configuration for O2 and VAC	Nos	1	1	1	0	1	0	0	4		
6.4.2	3 service alarm configuration for O2, MA4, VAC	Nos	2	3	2	3	1	1	3	15		
6.4.3	4 service alarm configuration for O2, N2O, MA4, VAC	Nos	5	5	4	4	2	3	1	24		
6.4.4	Supply, Installation, Testing and commissioning of Master alarm for four service configuration (Oxy, N2O, MA4 & Vac)	Nos	1	1	1	1	1	1	1	7		
<b>7</b>	<b>CEILING PENDANTS</b>											
7.1	<b>Ceiling Pendants for OT</b> : Supply, Installation, Testing and commissioning of Rigid Ceiling Pendant with 6 nos. of Gas & Vacuum Outlets (2-Oxygen, 1-N2O, 1-Air & 2-Vac) and 2 sets of 6/16 Amp Electrical sockets with switches	Nos	7	5	7	5	2	5	1	32		

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
8	<b>ACCESSORIES for Suction &amp; Oxygen Therapy</b>											
8.1	<b>Oxygen Flowmeter &amp; Humidifier Bottle with Adapter:</b> Back Pressure Compensated Flow meter within a range of 0-15 LPM where 0-5 LPM should be with expanded scale. Humidifier bottle should be made of unbreakable polycarbonate materials and autoclavable at 121 degree Centigrade (to be supplied along with required low pressure tubing and face mask)	Nos	62	34	49	40	29	22	42	278		
8.2	<b>The vacuum unit :</b> It shall include vacuum regulator along with 0-760 mm of Hg vacuum gauge, 600 ml capacity reusable poly carbonate collection bottle with overflow safety trap and autoclavable at 121 degree Centigrade with	Nos	62	34	49	40	29	22	42	278		

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferrin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
	plastic slide wall mounted type (to be supplied along with required low pressure tubing with canula).											
8.3	<b>Theatre Vacuum Unit:</b> It shall be trolley mounted. The unit shall include one regulator along with 0-760 mm of Hg vacuum gauge mounted on the trolley stand, having two reusable collection bottles each of 2000 ml capacity and made of unbreakable polycarbonate materials, autoclavable at 121 degree Centigrade, having over flow safety trap, mounted on the base of trolley unit made of aluminium along with castor wheels and connected with regulator & low pressure tube inter-connections (to be supplied along with required low pressure tubing with canula).	Nos	7	5	7	5	2	5	1	32		



Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision						Changed Clause / Provision		
Sl. No.	Description of Work	Unit	Name of the facility							Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferrin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
9	MISCELLANEOUS											
9.1	Supply, installation and operation of 30 KVA Silent Diesel Generator alongwith 3 phase AMF panel complete with necessary electrical cabling, exhaust piping etc.	Set	1	1	1	1	1	1	1	7		
9.2	Turnkey - for both Civil & Electrical work wherever necessary 1	Lot	1	1	1	1	1	1	1	7		
	<b>Total for Design, Supply, Installation, Commissioning of MGPS for all hospitals (excluding GST)</b>											
	<b>One Year Operation and Comprehensive Maintenance Charges from the date of commissioning (excluding GST)</b>											
	<b>Comprehensive Operation &amp; Maintenance Charges for the 2<sup>nd</sup> Year (excluding GST)</b>											
	<b>Comprehensive Operation &amp; Maintenance Charges for the 3<sup>rd</sup> Year (excluding GST)</b>											

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision					Changed Clause / Provision			
Sl. No.	Description of Work	Unit	Name of the facility						Total Quantity	Basic Rate in INR (excluding GST)	Amount in INR	
			Barasat DH	Basirhat DH	Bongaon SDH	BN Bose SDH, Barrack pore	Abinash Dutta Mat. Home	Lady Dufferrin Hospital	ID & BG, Beleg hata	(A)	(B)	(C)=(A)x(B)
	Comprehensive Operation & Maintenance Charges for the 4 <sup>th</sup> Year (excluding GST)											
	Comprehensive Operation & Maintenance Charges for the 5 <sup>th</sup> Year (excluding GST)											

**NOTES:**

- a) Gas/Vacuum outlets as mentioned above should be supplied along with matching adapter
- b) Oxygen flowmeters, ward vacuum units and theatre vacuum units should be supplied with necessary tubing, face mask / canula and catheter
- c) Consumables referred under comprehensive maintenance excludes gas & electricity charges
- d) Final payment will be processed based on actual measurement of work executed at site as per approved drawing by WBMSCL after commissioning.
- e) Same rates should be quoted for all 7(seven) hospitals. Evaluation of the bidder will be done on the basis of the sum total of BOQs of all 7(seven) hospitals, excluding the GST amount.
- f) Selected Bidder will be awarded the contract for all 7(seven) hospitals.

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision	Changed Clause / Provision
---------	----------	---------	-----------------	----------------------------	----------------------------

**Abbreviations**

**RH=Rural Hospital**

**SDH=Sub Divisional Hospital**

**DH=District Hospital**

Form 15 is to be added in Section - IV of the Bidding Documents (Bidding Forms) as follows:

**FORM - 15**

**STATEMENT OF BREAKUP OF DUTIES AND TAXES**

Sl. No.	Description of work	Percentage	Price (in INR)
1	Total for Design, Supply, Installation, Commissioning of MGPS for all Hospitals (excluding GST)	—	
2	GST as applicable on Design, Supply, Installation, Commissioning of MGPS for all Hospitals		
3	One Year Operation and Comprehensive Maintenance Charges from the date of commissioning (excluding GST)	—	
4	GST as applicable on One Year Operation and Comprehensive Maintenance Charges from the date of commissioning		
5	Comprehensive Operation & Maintenance Charges for the 2 <sup>nd</sup> Year (excluding GST)	—	
6	GST as applicable on Comprehensive Operation & Maintenance Charges for the 2 <sup>nd</sup> Year	GST at actuals	GST at actuals

Sl. No.	Page No.	Section	Clause/ Sl. No.	Current Clause / Provision	Changed Clause / Provision	
7		Comprehensive Operation & Maintenance Charges for the 3 <sup>rd</sup> Year (excluding GST)			—	
8		GST as applicable on Comprehensive Operation & Maintenance Charges for the 3 <sup>rd</sup> Year			GST at actuals	GST at actuals
9		Comprehensive Operation & Maintenance Charges for the 4 <sup>th</sup> Year (excluding GST)			—	
10		GST as applicable on Comprehensive Operation & Maintenance Charges for the 4 <sup>th</sup> Year			GST at actuals	GST at actuals
11		Comprehensive Operation & Maintenance Charges for the 5 <sup>th</sup> Year (excluding GST)			—	
12		GST as applicable on Comprehensive Operation & Maintenance Charges for the 5 <sup>th</sup> Year			GST at actuals	GST at actuals

**NOTES:**

- a) HSN Number to be specified by the bidder at the time of quoting the GST applicable
- b) GST amount is to be specified in Rupees on the basis of the prevailing rate of GST at the time of submission of Financial Bid